



MANGLA JOINT VENTURE

MANGLA FIELD OFFICE, WAPDA COLONY, MANGLA
PABX-0544-638142 Tel: 0544-638067-68, 639658 Fax No. 639034
E-mail: fomjv@yahoo.com

Ref: MJV/CM/MDR-37/28095

30th January 2009
RECEIVED

M/s Siemens (Pakistan) Engg. Co. Ltd
Site Office, New City
Mirpur AJK

02 FEB 2009

Installation Solutions

MANGLA DAM RAISING PROJECT CONTRACT NO. MDR-37: ELECTRIFICATION IN NEW CITY

APPROVAL OF SOURCE FOR PROCUREMENT OF REINFORCEMENT STEEL


- Reference. 1) 67 OP-1818/IS-48-A dated 22nd January, 2009
2) 67 OP-1818/IS-48 dated 19th January, 2009



Gentlemen,

Ittehad Steel, Plot # 417, I-9, Islamabad is hereby approved as manufacturer of steel for reinforcement and that for making J-bolts / anchor bolts. However, the Contractor shall be responsible

- i. To ensure that the steel, both reinforcing as well as that for making bolts, brought at site conforms to the standards of ASTM 615 A. This approval of manufacturer does not absolve the Contractor of his responsibility that all the procured articles qualify the respective specifications.
- ii. To produce vouchers / certificate from the manufacturer indicating Heat No. along with results of tests performed on the steel.
- iii. To arrange, at his own cost, chemical analysis and testing of the steel brought at site by a third party to the satisfaction of the Engineer in order to ensure that the steel meets the requirements of ASTM 615 A. Samples for such analysis / testing shall be collected from the steel bought at the site and the analysis / testing shall be done by or in the presence of a designated representative of the Engineer.

Yours truly,


Manzoor Ali
Construction Manager


Mr. Zaheer A. Nasir

Mr. Aziz
For info

- CC: 1) Chief Engineer/Project Director, Mangla Dam Raising Project, WAPDA, Mangla.
2) Superintending Engineer (Resettlement), MDRP, WAPDA, Mirpur.
3) Chief Resident Engineer (UD) MJV, Mangla.
4) Resident Engineer (MDR-37) MJV, Mangla.
5) Manager C/Lab. MJV, Mangla.
6) File.