



Designmen

CONSULTING ENGINEERS (Pvt) Ltd.

1st Floor, 9-West, Rizwan Plaza,
Jinnah Avenue, F-6, ISLAMABAD-PAKISTAN.
E-mail: najib@isb.comsats.net.pk
Web site: <http://www.designmen.com>
Ph: 92-51-2828577, 2829002
Fax: 92-51-2829891

N-90/2001
September 7, 2002

The Secretary
Board of Intermediate
And Secondary Education
Abbottabad.

SUBJECT: CONSTRUCTION OF B.I.S.E. COMPLEX, ABBOTTABAD

Dear Sir,

This is with reference to your letter No. 84/Project/BISE/ATD dated September 04. 2002.

We find the results of Itehad Steel better than those of **Faisal** and **Nomco** Steel. Therefore we recommend the Itehad Steel for use at BISE Complex.

In case of PVC pipe 4" dia pipe instead of 6" dia RCC pipe for seepage drain is recommended for the class B as per BSS 3056: 1986 and PSI 3051: 1991.

The documents are attached for your ready references.

Yours Sincerely,



(MUJEEB AHMED)
for DESIGNMEN Consulting Engineers (Pvt.) Ltd.

C.C. M/s. Zain-ul-Abideen & Sons